

ADDENDUM NO. 2

**CITY OF HIALEAH
MULTIPURPOSE ADULT CENTER AT 300 UNIT ELDERLY HOUSING COMPLEX
2656 W. OKEECHOBEE RD.
HIALEAH, FLORIDA**

MARCH 7, 2013

TO ALL CONCERNED

The original Contract Documents, for the Project entitled CITY OF HIALEAH – MULTIPURPOSE ADULT CENTER AT 300 UNIT ELDERLY HOUSING COMPLEX-STRUCTURAL/BUILDING SHELL-BID NO. 2012/13-3230-00-028 is hereby amended as noted in this Addendum No. 2.

This **Addendum No. 2** consists of **2** Typed Pages, **1** Sketch, **0** Attachments and **0** Drawings. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:  Date: March 7, 2013
Carlos Lopez – Acting Purchasing Director

ACKNOWLEDGEMENT

Receipt of this **Addendum No. 2** shall be acknowledged in the space provided on the ADDENDUM RECEIPT FORM (ARF) (copy attached) now a part of the Contract Documents and to be faxed immediately to City of Hialeah @ (305) 687-2642 and submitted with sealed bids.

IN THE CONTRACT DOCUMENTS:

Please revise “ADVERTISEMENTS AND INVITATION FOR BIDS” form as follows:

Sealed, written bids will be received by the office of the City Clerk of the City of Hialeah, Florida, 501 Palm Avenue until 11:00 a.m., Tuesday, March 19, 2013 at which time all bids will be publicly opened and read aloud in the Council Chambers for furnishing the following:

Response to RFI from Construct Group Corp. dated 3/6/13:

1. Could you please confirm what is the depth of the concrete arch? (Detail 8 at sheet S4.01)
The depth of concrete arches depicted in Detail 8 at sheet S4.01 varies. Dimensional criteria for the arches is found on detail 1, sheet A4.01 titled South Elevation. The bottom of each of the three arches all start at elevation +10'-0" AFF (to coincide with the tops of the columns) and rise in accordance with the two radiuses noted (6'-6" for the center arch and 4'-2" for the smaller arches). The overall gabled pediment itself is sloped at a 5 in 12 slope starting at elevation +12'-0" AFF. Reference sketch attached for clarification

2. The information I need to know is the thickness of the concrete arch (6", 8", 12" ???)
The width of the concrete arch is 16" to match the masonry columns below.

STRUCTURAL/BUILDING SHELL-2012/13-3230-00-028

**PAGE 2 OF 2
END OF ADDENDUM NO. 2**

ADDENDUM RECEIPT FORM

**CITY OF HIALEAH
MULTIPURPOSE ADULT CENTER AT 300 UNIT ELDERLY HOUSING COMPLEX
2656 W. OKEECHOBEE RD.
HIALEAH, FLORIDA**

CONTRACTOR'S NAME _____

ADDRESS _____

PHONE NO. _____ **FAX NO.** _____

CONTACT NAME _____ **SIGNATURE** _____

THE BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUM BY SIGNING AND DATING BELOW: (COPY OF THIS FORM MUST BE FAXED AND IMMEDIATELY TO CITY of HIALEAH @ (305) 687-2642 AND SUBMITTED WITH THE BID.

ADDENDUM

SIGNATURE

DATE

2

STRUCTURAL/BUILDING SHELL BID #2012/13-3230-00-028

ARF

